

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units mg/L Guidelines for Canadian Drinking Water Quality 7	mg/L 10	mg/L 1	mg/L
Admirals Beach	Admiral's Beach	2 Well Fields	Jan 16, 2024	0.23	LTD	0.01	2.20
Appleton	Appleton (+Glenwood)	Gander Lake (The Outflow)	Feb 21, 2024	0.01	0.14	LTD	7.00
Badger	Badger	Well Field, 2 wells on standby	Feb 07, 2024	0.20	LTD	LTD	LTD
Baine Harbour	Baine Harbour	Dug	Mar 04, 2024	0.03	0.52	LTD	0.68
Barachois Brook	Barachois Brook	Drilled	Feb 29, 2024	0.14	LTD	LTD	LTD
Bauline	Bauline	#1 Brook Path Well	Feb 22, 2024	0.05	LTD	LTD	5.10
Bay Roberts	Bay Roberts	Rocky Pond	Jan 16, 2024	0.01	0.07	LTD	2.00
Bay St. George South	Heatherton	#1 Well Heatherton (Home Hardware)	Feb 27, 2024	2.00	LTD	LTD	1.40
Bay St. George South	Jeffrey's	#1 Well Jeffery's (Joe Curnew)	Feb 27, 2024	1.10	LTD	LTD	LTD
Bay St. George South	Robinson's	#1 Well Robinson's (Louie MacDonald)	Feb 27, 2024	0.20	2.70	LTD	0.53
Bay St. George South	St. Fintan's, St. David's	#1 Well St. Fintan's (The Y)	Feb 27, 2024	0.35	LTD	LTD	LTD
Bay St. George South	Jeffrey's	#2 Well Jeffery's (Calvin Madore)	Feb 27, 2024	1.20	0.06	LTD	0.78
Bay St. George South	St. Fintan's	#2 Well St. Fintan's (Louis King)	Feb 27, 2024	0.25	1.40	LTD	0.79
Bay St. George South	McKay's	#2B Lions Club Well	Feb 27, 2024	0.93	LTD	LTD	0.75
Bay St. George South	Highlands	#3 Brian Pumphrey Well Highlands	Feb 27, 2024	0.67	LTD	LTD	LTD
Bay St. George South	Jeffrey's	#3 Well Jeffery's (Sid Shears)	Feb 27, 2024	3.00	LTD	LTD	1.60
Bay St. George South	Robinson's	#3 Well Robinson's (Gales)	Feb 27, 2024	0.37	LTD	LTD	LTD
Bay St. George South	McKay's	#3 Woodworth Well McKay's	Feb 27, 2024	0.20	LTD	LTD	1.00
Bay St. George South	Lock Leven	#6 Well Loch Leven (Jerry Quilty)	Feb 27, 2024	0.16	0.36	LTD	LTD
Bay St. George South	McKay's	#7 Well McKay's (Gordon Hulan)	Feb 27, 2024	0.47	LTD	LTD	1.90
Benoit's Siding	Doyles	# 2 Well Doyles	Mar 13, 2024	1.80	0.07	LTD	LTD
Benoit's Siding	Benoit's Siding (aka Bennett's Siding)	Drilled	Mar 13, 2024	0.73	0.91	0.01	0.59
Benton	Benton	Little Pond	Feb 28, 2024	0.02	LTD	LTD	12.00
Birchy Bay	Birchy Bay	Jumper's Pond	Feb 20, 2024	0.02	0.16	LTD	10.00
Bishop's Falls	Bishop's Falls	Northern Arm Lake	Jan 22, 2024	0.01	LTD	LTD	2.00
Black Duck	Black Duck (Siding)	#1 Well	Mar 05, 2024	0.11	0.25	LTD	LTD
Black Duck	Black Duck (Siding)	#2 Well	Mar 05, 2024	0.11	0.12	LTD	LTD
Blaketown	Blaketown South	#1 Selby Mercer Well	Feb 01, 2024	0.07	1.80	LTD	LTD
Blaketown	Blaketown	#2 Daphne Pincent Well	Feb 01, 2024	0.09	0.15	0.01	0.52
Blaketown	Blaketown Centre	#3 Fred Osborne Well	Feb 01, 2024	0.06	LTD	LTD	1.70
Blaketown	Blaketown North	#4 Hilda Barrett Well	Feb 01, 2024	0.12	LTD	LTD	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units	mg/L	mg/L	mg/L	mg/L
			Guidelines for Canadian Drinking Water Quality	7	10	1	
Branch	Branch	Drilled Wells	Feb 29, 2024	0.03	0.07	LTD	5.80
Brent's Cove	Brent's Cove	Paddy's Pond	Feb 28, 2024	0.01	LTD	LTD	16.00
Brigus South	Forge Hill area	#1 Well Forge Hill	Jan 23, 2024	0.37	LTD	LTD	2.90
Brigus South	Dunphey's Hill area	#2 Well Dunphey's Hill	Jan 23, 2024	0.44	LTD	LTD	0.66
Brigus South	Near highway	#3 Well Main Road	Jan 23, 2024	0.03	0.10	LTD	LTD
Bryant's Cove	Bryant's Cove South Side	#1 Well - Bert James Well #2 Well - Baxter Bowering Well	Jan 25, 2024	0.06	0.24	LTD	0.65
Bunyan's Cove	Bunyan's Cove	#1 Wellfield	Feb 28, 2024	0.05	0.23	LTD	3.80
Canning's Cove	Centre Canning's Cove	#3 Well - Glenda Penney	Feb 28, 2024	0.05	0.21	LTD	LTD
Cape Freels North	Cape Freels North	Long Pond	Feb 21, 2024	0.01	0.09	LTD	21.00
Cavendish	North Side Cavendish	#1 Well - Max Bishop	Feb 02, 2024	0.19	4.00	LTD	0.75
Cavendish	North Side Cavendish	#2 Well - Tom Critch	Feb 02, 2024	0.18	LTD	LTD	3.10
Centreville-Wareham-Trinity	Trinity	Southwest Feeder Pond	Feb 28, 2024	0.01	LTD	LTD	4.20
Chance Cove	Lower Cove	#5B Albert Rowe Well	Feb 01, 2024	0.44	LTD	LTD	1.70
Chance Cove	Upper Cove	Hollett's Well	Feb 01, 2024	0.09	0.12	LTD	1.30
Chance Cove	New Housing Area	New Housing Area Well	Feb 01, 2024	0.60	0.10	LTD	0.91
Chance Cove	Back Cove Area	Olive Smith Well	Feb 01, 2024	0.14	0.37	LTD	LTD
Channel-Port aux Basques	Channel-Port Aux Basques	Gull Pond & Wilcox Pond	Feb 12, 2024	0.01	0.05	LTD	1.20
Clareville	Clareville, Shoal Harbour	Shoal Harbour River	Feb 28, 2024	0.01	0.09	LTD	2.30
Clarke's Beach	Otterbury	#1 Well - Quinlon Well	Mar 13, 2024	0.16	LTD	LTD	LTD
Clarke's Beach	Otterbury	#2 Well - Delaney Well	Feb 07, 2024	0.10	0.09	LTD	LTD
Colliers	Merrigan's Lane + Main Rd	#2 Well - Merrigan's Well	Mar 05, 2024	0.23	0.19	LTD	LTD
Colliers	Harbour Drive & Main Road	#3 Well - Griffin's Well	Mar 05, 2024	0.17	0.44	LTD	0.98
Colliers	Harbour Drive	#4 Well - Flynn's Well	Feb 21, 2024	0.09	0.26	LTD	LTD
Colliers	Harbour Drive	#5 Well - Whalen's Well	Feb 21, 2024	0.11	1.60	LTD	0.56
Conception Bay South	Conception Bay South	Bay Bulls Big Pond	Feb 13, 2024	0.01	0.06	LTD	2.10
Conception Harbour	Cemetery Road & Main Road	Cemetery Road Well	Feb 21, 2024	0.08	0.51	LTD	0.61
Conception Harbour	Lower Bacon Cove	Lower Bacon Cove Well	Feb 21, 2024	0.66	0.43	LTD	0.68
Conception Harbour	Old Road and Coles Crescent	Old Road Well	Feb 21, 2024	0.24	0.11	LTD	0.53
Conception Harbour	Upper Bacon Cove, Kitchuses	Upper Bacon Cove Well	Feb 21, 2024	0.36	0.12	LTD	0.69
Corner Brook	Corner Brook (+Massey Drive, +Mount Moriah)	Trout Pond, Third Pond (2 intakes)	Feb 13, 2024	0.01	0.09	LTD	1.40
Cox's Cove	Upper Area	Upper Area Wellfield	Feb 29, 2024	0.39	0.10	LTD	0.68
Deadman's Bay	Deadman's Bay	Deadman's Pond	Feb 21, 2024	0.01	LTD	LTD	8.90

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units mg/L Guidelines for Canadian Drinking Water Quality	mg/L 10	mg/L 1	mg/L
Eastport	Eastport (+Sandy Cove)	Dug	Mar 05, 2024	0.03	0.32	LTD	LTD
Fermeuse	Fermeuse	Port Kirwan Road Well	Jan 23, 2024	0.15	0.87	LTD	LTD
Flat Bay	Flat Bay (East)	#1 Well	Feb 29, 2024	0.11	LTD	LTD	LTD
Flat Bay	Flat Bay (East)	#3 Well	Feb 29, 2024	0.07	0.94	LTD	LTD
Flat Bay West	Flat Bay West	#3 Well	Feb 29, 2024	0.32	0.95	LTD	0.53
Fleur de Lys	Fleur De Lys	First Pond, Narrow Pond	Feb 22, 2024	0.01	LTD	LTD	18.00
Fox Roost-Margaree	Fox Roost-Margaree	Drilled Well and Margaree Pond	Feb 12, 2024	0.01	0.11	LTD	9.90
Fox Roost-Margaree	Fox Roost-Margaree - PWDU	Drilled Well and Margaree Pond	Feb 12, 2024	LTD	LTD	LTD	LTD
Frenchman's Cove	Frenchman's Cove	Dug Well	Mar 05, 2024	0.02	0.06	LTD	4.80
Freshwater	Freshwater (Carbonear)	#2 Well - Covage's Lane Well	Jan 25, 2024	0.04	0.11	LTD	LTD
Freshwater	Freshwater (Carbonear)	#3 Well - Wallace Snow Well	Jan 25, 2024	0.24	2.00	LTD	0.51
Gander	Gander	Gander Lake	Feb 21, 2024	0.01	0.18	LTD	6.00
Gander Bay South	Gander Bay South - PWDU	Barry's Brook	Feb 21, 2024	LTD	LTD	LTD	LTD
Gander Bay South	George's Point, Harris Point	Barry's Brook	Feb 21, 2024	0.01	0.23	LTD	12.00
Gaskiers	Gaskiers-Point La Haye - PWDU	Well	Jan 16, 2024	0.00	LTD	LTD	LTD
Georgetown	Georgetown	Drilled	Mar 05, 2024	0.09	0.30	LTD	LTD
Grates Cove	Grates Cove Centre	#1C Well	Jan 23, 2024	0.09	LTD	LTD	0.70
Grates Cove	Grates Cove North End	#3 Frank Janes Well	Jan 23, 2024	0.06	LTD	LTD	1.80
Grates Cove	Grates Cove South End	#4 Stoyles Hill Well	Jan 23, 2024	0.06	0.12	0.01	0.69
Great Codroy	Great Codroy East	#1 Well	Mar 13, 2024	2.80	0.09	0.01	LTD
Great Codroy	Great Codroy West	#2 Well	Mar 13, 2024	0.38	0.32	0.02	LTD
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Spring Gulch	Feb 26, 2024	0.02	LTD	LTD	LTD
Happy Valley-Goose Bay	Happy Valley-Goose Bay	Well Field (connect summer 2002)	Feb 26, 2024	0.04	LTD	LTD	0.62
Harbour Grace	Thickett	#1 Thicket Susie Galway Well	Feb 13, 2024	0.03	0.62	LTD	LTD
Harbour Grace	Thickett	#2 Thicket New Well	Feb 13, 2024	0.07	0.35	LTD	LTD
Harbour Grace	Riverhead	Mercer's Rd. Well	Mar 13, 2024	0.04	0.33	LTD	LTD
Harbour Grace	Harbour Grace South Lower	New Southside Well (Well#3)	Feb 13, 2024	0.12	LTD	LTD	LTD
Harbour Grace	Harbour Grace South Upper	Southside Wellfield (Well #1 & #2)	Feb 13, 2024	0.08	LTD	LTD	LTD
Harbour Main-Chapel's Cove-Lakeview	Harbour Main, Chapel's Cove, Lakeview	Flynn's Hill Well	Feb 20, 2024	0.26	0.72	LTD	0.85
Harbour Main-Chapel's Cove-Lakeview	Harbour Main, Chapel's Cove, Lakeview	Holden's Road Well	Feb 20, 2024	0.10	0.43	LTD	LTD
Harbour Mille-Little Harbour East	Harbour Mille, Little Harbour East (Fortune Bay)	Well	Mar 04, 2024	0.51	0.05	LTD	6.00

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
			Units Guidelines for Canadian Drinking Water Quality	mg/L 7	mg/L 10	mg/L 1	mg/L
Harbour Mille-Little Harbour East	Harbour Mille, Little Harbour East (Fortune Bay)	Well	Mar 15, 2024	0.46	0.06	LTD	5.60
Harry's Harbour	Harry's Harbour	#2 Well - Northwest Hill / Country Road	Feb 20, 2024	0.15	LTD	LTD	0.92
Heart's Content	Heart's Content	Southern Cove Pond	Jan 25, 2024	0.01	LTD	LTD	5.10
Holyrood	Holyrood	Main Line	Feb 20, 2024	0.12	0.13	LTD	LTD
Holyrood	Holyrood	O'Connell's Well	Feb 20, 2024	0.32	0.06	LTD	3.00
Holyrood	Holyrood	Woodford Station - Healey's Well and Quinlan's Well	Feb 20, 2024	0.39	LTD	LTD	4.20
Hopeall	Hopeall	Charles Cumby Well	Feb 02, 2024	0.07	0.21	LTD	0.61
Hopeall	Gilberts Hill	Gilberts Hill Well	Feb 02, 2024	0.07	0.76	LTD	0.69
Humber Arm South	Frenchman's Cove Area	Gurges Pond	Feb 12, 2024	0.05	LTD	LTD	4.50
Jean de Baie	Jean de Baie	#1 Well	Mar 06, 2024	0.08	0.20	LTD	0.53
King's Point	King's Point	Bulley's Pond	Feb 16, 2024	0.01	0.07	LTD	5.90
Kippens	Kippens	Well Field	Feb 26, 2024	0.11	0.16	LTD	LTD
Labrador City	Labrador City	Beverly Lake	Mar 04, 2024	0.02	0.05	LTD	1.30
Lance Cove	Lance Cove	Local Service District Well	Feb 21, 2024	1.30	0.30	LTD	0.75
Lewisporte	Lewisporte	Stanhope Pond	Jan 23, 2024	0.02	0.09	LTD	9.10
Mainland	Mainland	Caribou Brook	Feb 27, 2024	0.06	0.36	LTD	2.50
Makinsons	Turkswater & Hodgewater Line West	Country Path Wells	Feb 13, 2024	0.04	0.07	LTD	LTD
Marystown	Marystown	Fox Hill Reservoir / Clam Pond	Mar 06, 2024	0.01	LTD	LTD	2.40
Marysvalle	Marysvalle, Long Pond	Drilled	Mar 05, 2024	0.02	LTD	LTD	LTD
Mattis Point	Mattis Point	Drilled	Mar 14, 2024	0.13	LTD	LTD	LTD
McCallum	McCallum	Drilled	Mar 06, 2024	0.04	0.10	LTD	11.00
Mount Pearl	Mount Pearl	Bay Bulls Big Pond	Feb 13, 2024	0.01	0.06	LTD	1.80
New Harbour	New Harbour	Williams Hill Well	Jan 25, 2024	0.13	0.08	LTD	0.67
Norris Arm	Norris Arm (south)	Mill Lake	Jan 23, 2024	0.01	LTD	LTD	5.10
North West River	North West River	Wellfield (Well # 1 & Well # 2)	Mar 12, 2024	0.16	LTD	LTD	LTD
O'Donnells	O'Donnell's	Well Field	Jan 16, 2024	0.08	0.13	LTD	LTD
O'Regans East	O'Regan's East	Drilled	Mar 13, 2024	0.32	0.96	0.02	0.61
Paradise	Paradise	Bay Bulls Big Pond	Feb 13, 2024	0.01	0.06	LTD	1.80
Pasadena	Pasadena	Blue Gulch Pond	Feb 23, 2024	0.01	LTD	LTD	LTD
Petley	Petley	Drilled + Dug Reservoir	Feb 29, 2024	0.04	0.70	LTD	0.59
Piccadilly Slant-Abraham's Cove	Piccadilly Slant	#1 Well - Piccadilly Slant	Mar 05, 2024	0.29	0.34	LTD	1.10
Point of Bay	Point of Bay	Indian Cove Pond	Feb 12, 2024	0.01	0.06	LTD	8.60

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC	
				Units	mg/L	mg/L	mg/L	mg/L
				Guidelines for Canadian Drinking Water Quality				
Port Blandford	Port Blandford	Noseworthy's Pond	Feb 28, 2024	0.02	0.07	LTD	7.00	
Port Kirwan	Port Kirwan	Developed Spring	Jan 23, 2024	0.02	0.24	LTD	LTD	
Port Rexton	Ship Cove	#6 Well - Banister's Well	Mar 06, 2024	0.10	0.14	LTD	0.83	
Port Rexton	Champneys Arm	Champney's Arm Well	Mar 06, 2024	0.19	LTD	LTD	2.00	
Port au Port East	Port au Port East	Drilled Well - 75-80% Berry Head Watershed - 20-25%	Feb 20, 2024	0.07	0.23	LTD	1.60	
Port au Port West-Aguathuna-Felix Cove	Port au Port West, Aguathuna	#1 & #3 & #6 FatherJoy's Well	Feb 20, 2024	0.37	0.06	LTD	1.30	
Port au Port West-Aguathuna-Felix Cove	Felix Cove	#4-Goose Pond Road Well	Feb 28, 2024	0.18	0.17	LTD	1.00	
Port au Port West-Aguathuna-Felix Cove	Felix Cove	#5 Ocean View Drive Well	Feb 28, 2024	LTD	0.24	LTD	0.88	
Portugal Cove-St. Phillips	Portugal Cove-St. Phillips	Bay Bulls Big Pond	Feb 13, 2024	0.01	0.06	LTD	1.90	
Pouch Cove	Pouch Cove	North Three Island Pond	Feb 22, 2024	0.00	LTD	LTD	LTD	
Raleigh	Raleigh	#4 Well	Mar 06, 2024	0.20	0.06	LTD	1.70	
Ramea	Ramea	Northwest Pond	Jan 21, 2024	0.03	0.09	LTD	4.80	
Ramea	Ramea - PWDU	Northwest Pond	Jan 21, 2024	0.01	0.08	LTD	LTD	
Random Sound West	North West Brook, Ivany Cove	#1 Well - Cabot Road South Well	Mar 14, 2024	0.78	0.07	LTD	1.60	
Random Sound West	North West Brook, Ivany Cove	#2 Well	Mar 14, 2024	0.08	1.50	LTD	LTD	
Red Harbour	Red Harbour	1A Well Drilled + 1C Dug Well (back-up)	Mar 06, 2024	0.32	0.06	LTD	2.60	
Reidville	Reidville	Humber Canal, Grand Lake	Jan 30, 2024	0.01	0.13	LTD	3.50	
Renews-Cappahayden	Cappahayden	#1 Dinn's Well	Jan 19, 2024	0.31	0.07	LTD	LTD	
Riverhead	Riverhead (St. Mary's Bay)	Well Field	Jan 16, 2024	0.02	0.31	LTD	1.10	
Sandringham	Sandringham	Drilled	Mar 05, 2024	0.04	0.42	LTD	0.64	
Sandy Cove	Sandy Cove	Dug	Mar 05, 2024	0.03	0.33	LTD	LTD	
Sheaves Cove	Sheaves Cove	Drilled	Mar 04, 2024	0.06	0.29	LTD	1.70	
Sheppardville	Sheppardville	Drilled	Feb 22, 2024	0.06	LTD	LTD	3.50	
Sheshatshiu	Sheshatshui - Indian Band Council	Wells 1, 2 & 3	Mar 12, 2024	0.17	0.25	LTD	1.20	
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#1 Well - PJ's Variety Well	Mar 04, 2024	0.41	0.06	LTD	1.20	
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#2 Well - Howard & Rodney Jesso Well	Mar 04, 2024	0.26	0.16	LTD	1.50	
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#4B Well - Nancy Rowe Well	Mar 04, 2024	0.56	0.20	LTD	LTD	
Ship Cove-Lower Cove-Jerry's Nose	Ship Cove, Jerry's Nose	#5 Well - Murdock Wheeler Well	Mar 04, 2024	0.06	0.35	LTD	0.67	
Ship Cove-Lower Cove-Jerry's Nose	Lower Cove	#6 Well - Lower Cove Well	Mar 04, 2024	0.23	0.34	LTD	LTD	
Small Point-Adam's Cove-Blackhead-Broad Cove	Adam's Cove	#1 Well - Reg Bursey Well	Feb 07, 2024	0.32	0.27	LTD	0.71	

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC	
			Units	mg/L	mg/L	mg/L	mg/L	
			Guidelines for Canadian Drinking Water Quality					7
Small Point-Adam's Cove-Blackhead-Broad Cove	Blackhead + Adam's Cove	#4 Well - Leonard King Well	Feb 07, 2024		0.13	0.14	LTD	LTD
Small Point-Adam's Cove-Blackhead-Broad Cove	Broad Cove	#6 Well - Herb Trickett Well	Feb 07, 2024		0.56	0.22	LTD	0.53
Small Point-Adam's Cove-Blackhead-Broad Cove	Small Point	#8 Well - Effie Flight Wells	Feb 07, 2024		0.16	1.60	LTD	LTD
South Dildo	South Dildo	#5 Well - Calvin Reid Well	Jan 25, 2024		0.09	LTD	LTD	0.56
Springdale	Springdale Industrial Park	Well	Feb 09, 2024		0.12	0.37	LTD	LTD
St. Alban's	St. Alban's	Well Field	Jan 31, 2024		0.02	0.33	LTD	LTD
St. Andrews	St. Andrew's	#1 Well	Mar 13, 2024		0.92	0.49	0.02	0.95
St. Andrews	St. Andrew's	#2 Well	Mar 13, 2024		0.36	LTD	0.02	0.84
St. Andrews	St. Andrew's East	#3 Well	Mar 13, 2024		0.13	0.82	0.03	2.00
St. Andrews	Air Strip Road	#4 Well Strip Road Well	Mar 13, 2024		0.66	LTD	0.01	0.61
St. Anthony	St. Anthony	St. Anthony Pond	Mar 06, 2024		0.01	0.13	LTD	6.60
St. Bride's	St. Bride's	North Side Brook	Feb 29, 2024		0.02	LTD	LTD	2.70
St. Bride's	St. Bride's	South Side Brook	Feb 29, 2024		0.01	LTD	LTD	5.10
St. George's	St. George's	Wellfield	Feb 29, 2024		0.13	0.17	LTD	1.50
St. John's	St. John's (+Mt. Pearl, +Paradise, +Portugal Cove-St. Phillips, +CBS)	Bay Bulls Big Pond	Feb 13, 2024		0.01	0.06	LTD	2.20
St. John's	St. John's	Petty Harbour Long Pond	Feb 22, 2024		0.01	LTD	LTD	1.90
St. John's	St. John's	Windsor Lake	Feb 22, 2024		0.01	LTD	LTD	2.20
St. Joseph's	St. Joseph's S.M.B.	Drilled	Jan 16, 2024		0.13	LTD	LTD	1.40
St. Lunaire-Griquet	St. Lunaire-Griquet	Drilled	Mar 07, 2024		0.13	LTD	LTD	2.10
St. Mary's	St. Mary's	Wellfield	Jan 16, 2024		0.11	0.09	LTD	LTD
St. Patricks	St. Patricks	David Joy Well	Feb 09, 2024		0.07	LTD	LTD	LTD
St. Pauls	St. Pauls	Two Mile Pond	Feb 08, 2024		0.04	0.08	LTD	9.70
Stephenville	Stephenville	Well Field	Feb 26, 2024		0.13	0.19	LTD	LTD
Stephenville Crossing	Stephenville Crossing	Well Fields 1 & 2	Feb 26, 2024		0.10	0.31	LTD	LTD
Sunnyside (T.B.)	Sunnyside	Center Cove River	Feb 08, 2024		0.01	0.10	LTD	7.20
Swift Current	Swift Current (Hollett's Point)	Drilled	Feb 09, 2024		0.04	LTD	LTD	5.90
Terrenceville	Terrenceville	Big Brook	Mar 04, 2024		0.00	LTD	LTD	4.80
Tompkins	Tompkins	Greg Wall Well	Mar 13, 2024		0.21	0.24	0.02	LTD
Torbay	Torbay	North Pond	Feb 22, 2024		0.01	LTD	LTD	3.20
Upper Amherst Cove	Upper Amherst Cove	Drilled	Mar 06, 2024		0.13	LTD	LTD	2.20
Upper Ferry	Upper Ferry - Lower	#1 Well - Gerard Brownrigg Well	Mar 13, 2024		0.07	1.80	0.02	0.56
Upper Ferry	Upper Ferry - Middle	#2 Well - Hughie MacIlsac Well	Mar 13, 2024		0.25	0.10	LTD	LTD

Tap Water Quality for Public Water Supplies in Newfoundland and Labrador - Additional Parameters

Community Name	Serviced Area	Source Name	Sample Date	Strontium	Nitrate	Nitrite	TOC
				Units mg/L Guidelines for Canadian Drinking Water Quality 7	mg/L 10	mg/L 1	mg/L
Upper Ferry	Upper Ferry - Upper	#3 Well - Marshall Devoe Well	Mar 13, 2024	0.26	0.08	0.01	LTD
Upper Ferry	Upper Ferry	#4 Well - Angus MacNeil Well	Mar 13, 2024	0.41	0.18	0.01	LTD
Wabana	Wabana - PWDU	#3 Yard West Mines Road	Feb 21, 2024	LTD	LTD	LTD	LTD
Wabana	Wabana	#3 Yard West Mines Road	Mar 05, 2024	0.51	LTD	LTD	3.20
Wabana	Wabana	#4-West Mines Road	Feb 21, 2024	0.49	LTD	LTD	3.40
Wabana	Wabana	Middleton Ave	Mar 05, 2024	0.37	0.07	LTD	3.30
Wabana	Wabana	Mixed Supplies	Mar 05, 2024	0.43	LTD	LTD	2.00
Wabana	Wabana	Mixed Supplies	Mar 05, 2024	0.43	LTD	LTD	2.00
Wabana	Wabana	Mixed Supplies	Mar 05, 2024	0.42	LTD	LTD	1.90
Wabana	Wabana	Normore Crescent East #1	Mar 05, 2024	0.75	LTD	LTD	3.60
Wabana	Wabana	Quigley's Line	Mar 05, 2024	0.73	LTD	LTD	3.50
West St. Modeste	West St. Modeste	Well Field	Feb 28, 2024	0.01	LTD	LTD	4.40
Winterland	Winterland	Well Field	Mar 05, 2024	0.14	0.76	LTD	LTD

Tap water samples are collected semi annually from drinking water faucets of one or more homes, public buildings, or businesses in your community. Tap or treated water quality is monitored to check its compliance with the Guidelines for Canadian Drinking Water Quality (GCDWQ). Tap water quality is also monitored so that water that is being consumed at the tap can be compared with the untreated source water quality. Any variations between source and tap water quality represents the effectiveness of the treatment and disinfection system, and the influences of the distribution system due to plumbing in local homes, public buildings, or businesses. The values for each parameter are as reported by the lab and verified by the department.

This report for tap water provides a brief discussion and interpretation of health related water quality parameters, if any, that exceed the acceptable limits as set out in the GCDWQ. Guidelines have not been developed for all the parameters listed in this report.

Contaminants are substances that are known or suspected to cause adverse effects on the health of some people when present in concentrations greater than the established Maximum Acceptable Concentrations (MACs) or the Interim Maximum Acceptable Concentrations (IMACs) of the GCDWQ. Each MAC has been derived to safeguard health assuming lifelong consumption of drinking water containing the substance at that concentration. IMACs are reviewed periodically as new information becomes available. Please consult your Medical Officer of Health for additional information on the health aspects on contaminants. Contaminant exceedances are highlighted in **red text** and enclosed in a box.

The reported information is for supplies selected for sampling and may not include all public water supplies.

Contaminant Exceedances

Strontium: The maximum acceptable concentration for strontium is 7.0 mg/L. Strontium may enter drinking water from naturally occurring deposits or as a result of human activity, such as mining or other industries. High levels of this contaminant can cause adverse health effects for some people.

Nitrate: The maximum acceptable concentration for nitrate is 10 mg/L as nitrate-nitrogen. Nitrate is a naturally occurring ion that is widespread in the environment. High levels of this contaminant can cause adverse health effects for some people.

Nitrite: The maximum acceptable concentration for nitrite is 1 mg/L as nitrite-nitrogen. Nitrite is a naturally occurring ion that is widespread in the environment. High levels of this contaminant can cause adverse health effects for some people.

LTD - Less Than Detection Limit - The detection limit is the lowest concentration of a substance that can be determined using a particular test method and instrument. Detection limits vary from parameter to parameter and change from time to time due to improvements in analytical procedures and equipment.

mg/L = milligrams per litre or parts per million TOC = total organic carbon